

AMENDMENT TO RENEWABLE ENERGY APPROVAL
NUMBER 2344-9R6RWR
Issue Date: November 22, 2017

wpd White Pines Wind Incorporated
2233 Argentia Rd, No. 102
Mississauga, Ontario
L5N 2X7

Site Location: White Pines Wind Project
Prince Edward County, Ontario

You are hereby notified that I have amended Approval No. 2344-9R6RWR issued on July 16, 2015 for a Class 4 wind facility, as follows:

A. The definitions of "Acoustic Assessment Report" and "Application" are deleted and replaced with the following:

1. "Acoustic Assessment Report" means the reports included in the Application and entitled:

- a. *Noise Assessment Report, White Pines Wind Project*, dated October 20, 2014, prepared by HGC Engineering and signed by Ian R. Bonsma P.Eng. & Brian Howe P.Eng.; and
- b. *Appendix B (Noise Review)* of the document entitled *White Pines Wind Project Renewable Energy Approval Modification Document* prepared by Stantec Consulting Ltd., dated September 20, 2017, and signed by Rob Nadolny and Mark Knight.

11. "Application" means the application for a Renewable Energy Approval dated September 14, 2012, and signed by Khlaire Parré, Director of Renewable Energy Approvals, wpd White Pines Wind Incorporated, and an Addendum to the application for a Renewable Energy Approval dated August 2, 2013, and signed by Shawna Peddle, Senior Project Manager, Stantec Consulting Ltd., on behalf of wpd White Pines Wind Incorporated, and all supporting documentation submitted with the application, including amended documentation submitted up to July 15, 2015; and as further amended by the application for an amendment to a Renewable Energy Approval dated

October 10, 2017, and signed by Khlaire Parré, Director of Renewable Energy Approvals, wpd White Pines Wind Incorporated, and all supporting documentation submitted with the application, including amended documentation submitted up to the date this amendment is issued;

B. Schedule B of the Approval is modified to include the following entry:

Coordinates of the Equipment and Noise Specifications
 Coordinates of the Equipment are listed below in UTM, Z18-NAD83 projection:

Source ID	Maximum Sound Power Level (dBA)	Easting (m)	Northing (m)	Source Description
TS2b	98	332,911	4,862,991	South Transformer , 15/20 MVA

NOTES:

- a. The Sound Power Level reported above for the Transformer includes the 5 decibels (dB) adjustment for tonality as prescribed in Publication NPC-104.
- b. Only one (1) transformer substation (either TS2 or TS2b) will be positioned at the UTM coordinates noted in the above table.

This Notice shall constitute part of the approval issued under Approval No. 2344-9R6RWR dated July 16, 2015.

In accordance with Section 139 of the Environmental Protection Act, within 15 days after the service of this notice, you may by further written notice served upon the Director, the Environmental Review Tribunal and the Environmental Commissioner, require a hearing by the Tribunal.

In accordance with Section 47 of the Environmental Bill of Rights, 1993, the Environmental Commissioner will place notice of your request for a hearing on the Environmental Registry.

Section 142 of the Environmental Protection Act provides that the notice requiring the hearing shall state:

- a. The portions of the renewable energy approval or each term or condition in the renewable energy approval in respect of which the hearing is required, and;
- b. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The signed and dated notice requiring the hearing should also include:

1. The name of the appellant;
2. The address of the appellant;
3. The renewable energy approval number;
4. The date of the renewable energy approval;
5. The name of the Director;
6. The municipality or municipalities within which the project is to be engaged in;

This notice must be served upon:

The Secretary* Environmental Review Tribunal 655 Bay Street, 15th Floor Toronto, Ontario M5G 1E5	AND	The Environmental Commissioner 1075 Bay Street, 6th Floor Suite 605 Toronto, Ontario M5S 2B1	AND	The Director Section 47.5, <i>Environmental Protection Act</i> Ministry of the Environment and Climate Change 135 St. Clair Avenue West, 1st Floor Toronto, Ontario M4V 1P5
--	-----	---	-----	---

*** Further information on the Environmental Review Tribunal's requirements for an appeal can be obtained directly from the Tribunal at: Tel: (416) 212-6349, Fax: (416) 326-5370 or www.ert.gov.on.ca**

Under Section 142.1 of the Environmental Protection Act, residents of Ontario may require a hearing by the Environmental Review Tribunal within 15 days after the day on which notice of this decision is published in the Environmental Registry. By accessing the Environmental Registry at www.ebr.gov.on.ca, you can determine when this period ends.

Approval for the above noted renewable energy project is issued to you under Section 47.5 of the Environmental Protection Act subject to the terms and conditions outlined above.

DATED AT TORONTO this 22nd day of November,
2017

Mohsen Keyvani, P.Eng.
Director
Section 47.5, *Environmental Protection Act*

DM/
c: Area Manager, MOECC Belleville
c: District Manager, MOECC Kingston